

**Safety Recall Notice Consumer Product Safety Commission**

July 13, 2023

Washington, D.C. The Consumer Product Safety Commission, in cooperation with ECR International, Inc. of Utica, New York is voluntarily recalling approximately 1764 gas boilers. These boilers may potentially be missing the Flue Inspection Cover Plate located on the top of the boiler’s flue collector. Not all boilers are affected by this recall. Only boilers manufactured between December 5<sup>th</sup>, 2022 and January 24<sup>th</sup>, 2023 may be affected.

Voluntary Recall for ECR Cast Iron Boilers of the following branded products: Utica Boilers MGB-K, Dunkirk DXL-K, Pennco 15B-K, Green Mountain GMGW-K, Utica Heating UH15B-K, and Columbia MCB-K.

**Please carefully read the following information to help determine if your boiler is impacted by this recall.** The Boiler Name, Model Number and Serial Number can be found on the boiler rating plate located on the top panel of the boiler.

Boiler Rating Plate Location



Model Location



Serial Number Location



Manufactured for  
**ECR INTERNATIONAL**  
 2201 DWYER AVE, UTICA, NY 13504

**BOILER MODEL NO.**  
 15B-060K  
 UH15B-060K

**SERIES** **SERIAL NO.**  
012345678S

Certified Under: CSA/ANSI Z21.10.22 & CSA 4.9:22 Low Press. Boiler  
 ELECTRICAL CHARACTERISTICS  
 ELECTRIC 120 VOLTS, 60 HERTZ 1 PHASE LESS THAN 12 AMPERES  
 CATEGORY I  
 INPUT – 59,000 BTU/HR  
 CAPACITY – 50,000 BTU/HR  
 GAS TYPE – NATURAL GAS  
 GAS ORIFICE SIZE – #40  
 MAX GAS INLET PRESSURE – 13.5" W.C.  
 MIN GAS INLET PRESSURE – 5.0" W.C.  
 MANIFOLD GAS PRESSURE – 3.5" W.C.  
 FOR INSTALLATION ON COMBUSTIBLE FLOORING.  
 FOR USE ONLY WITH AUTOMATIC VENT DAMPER  
 DEVICE NO. 240006936. FOLLOW INSTALLATION INSTRUCTIONS.

**AHRI CERTIFIED**   
www.ahridirectory.org

NET AHRI RATING, WATER: 43 MBH  
 NET AHRI RATING, STEAM: N/A

---

**CERTIFIED BY  
 ECR INTERNATIONAL, INC**

 M.A.W.P. WATER 50 PSI  
 MINIMUM RELIEF VALVE CAPACITY  
 59 LBS./HR.  
 MAXIMUM WATER TEMPERATURE  
 195°F

SERIAL NUMBER 042000371S  


615000593

Brand Name	Boiler Model Number	Serial Number Range	Product Images
<b>Dunkirk</b>	<b>DXL-K:</b>  DXL-060K DXL-095K DXL-120K DXL-150K DXL-175K DXL-205K DXL-235K	<b>Serial Number Range:</b>  392201652s thru 402202738s 012302567s and 012302571s	
<b>Utica Boilers</b>	<b>MGB-K:</b>  MGB-060K MGB-095K MGB-120K MGB-150K MGB-175K MGB-205K MGB-235K	<b>Serial Number Range:</b>  402200481s thru 402202693s 012302268s thru 012302566s	
<b>Columbia</b>	<b>MCB-K:</b>  MCB-060K MCB-095K MCB-120K MCB-150K MCB-175K MCB-205K MCB-235K	<b>Serial Number Range:</b>  402201449s thru 402202214s	
<b>Utica Heating</b>	<b>UH15B-K:</b>  UH15B-060K UH15B-095K UH15B-120K UH15B-150K UH15B-175K UH15B-205K UH15B-235K	<b>Serial Number Range:</b>  392201654s thru 402202800s 012302274s thru 012303099s	

<p><b>Pennco</b></p>	<p><b>15B-K:</b></p> <p>15B-060K 15B-095K 15B-120K 15B-150K 15B-175K 15B-205K 15B-235K</p>	<p><b>Serial Number Range:</b></p> <p>392202597s thru 402202806s 012301918s thru 012303055s</p>	
<p><b>Green Mountain</b></p>	<p><b>GMGW-K:</b></p> <p>GMGW-060K GMGW-095K GMGW-120K GMGW-150K GMGW-175K GMGW-205K GMGW-235K</p>	<p><b>Serial Number Range:</b></p> <p>392201653s thru 402202686s 012301924s thru 012301961s</p>	

**Hazard:** If the Boiler is missing the Flue Inspection Cover Plate; the boiler can emit flue gases creating a carbon monoxide hazard.

**Incidences and Injuries:** ECR International has received no reports of carbon monoxide leaks or incidences related to this issue, and no injuries or deaths have been reported.

**Remedy:** Consumers should stop using recalled products immediately. Consumers with the recalled boilers should immediately contact the installer to schedule a free boiler safety inspection and repair or contact ECR International recall hotline at 1-800-241-5501.

We apologize for any inconvenience this may cause and ask your assistance with repairing the affected boilers. If you have any questions, please feel free to contact our Customer Service Department at our specially designated toll-free Hot Line, 1-800-241-5501.



Peter Desens  
Director of Technical Affairs  
ECR International, Inc.